

**AMENDMENT OF
SOLICITATION**

1. AMENDMENT NO. 4	2. EFFECTIVE DATE – January 16, 2023	3. PAGE 1 OF 1
---------------------------	---	-----------------------

4. ISSUED BY: **Fluor-BWXT Portsmouth LLC**
P.O. Box 548
Piketon, OH 45661

5. NAME AND ADDRESS OF CONTRACTOR (<i>Name, street, county, state &, zip code</i>)	6. AMENDMENT OF (RFP) SOLICITATION NO. FBP22SC112978	DATE December 19, 2022
--	---	-------------------------------

7. The above numbered solicitation is amended as set forth in Item 8. The hour and date specified for receipt of Offers X is extended, ___ is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:

(a) By completing Items 5 and 9, and returning one (1) copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. **FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.** If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

8. DESCRIPTION OF AMENDMENT

Except as provided herein, all terms and conditions of the document remain unchanged and in full force and effect.

- The due date for proposals regarding the X-333 Exterior Bulk ACM Abatement project has been extended until January 23, 2023 at 12:00 P.M. Eastern.**
- Please see the attached additional Questions and Answers. The attachment will be embedded into this document.**
- Clarification of Manual Lifting – Full Transite Panels weigh approximately 150 lbs per panel. Company Site General Work Job Hazard Analysis JHA FBP-JHA-13-1647 restricts lifting to no more than 50 lbs per individual.**

Include a signed and acknowledged copy of this Amendment with your proposal.

		10A. Fluor BWXT Portsmouth LLC Bruce Knauff	
9B. CONTRACTOR/OFFEROR _____ (Signature)	9C. DATE SIGNED	10B. _____ (Signature)	10C. DATE SIGNED 01/16/2023

