

AMENDMENT OF SOLICITATION

1. AMENDMENT NO.

5

2. EFFECTIVE DATE –

February 21, 2023

3.

PAGE 1 OF 2

4. ISSUED BY: **Fluor-BWXT Portsmouth LLC**
P.O. Box 548
Piketon, OH 45661

5. NAME AND ADDRESS OF CONTRACTOR (*Name, street, county, state & zip code*)

6. AMENDMENT OF (RFP) SOLICITATION NO.

FBP23SC113771

DATE

January 25,
2023

7. The above numbered solicitation is amended as set forth in Item 8. The hour and date specified for receipt of Offers X is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:

(a) By completing Items 5 and 9, and returning one (1) copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

8. DESCRIPTION OF AMENDMENT

Except as provided herein, all terms and conditions of the document remain unchanged and in full force and effect.

1. Questions and answers.

a. **Can the 4” sanitary water be changed from DIP to HDPE?**

No, needs to remain DIP.

b. **Note 18 on C-20104 requires a “temporary means of containment”. Please clarify what this means of containment should be.**

Disregard, not included in this scope of scope.

c. **Please confirm that Storage Tank T-200 and the pipe bridge are not in this scope of work.**

Disregard, not included in this scope of work.

d. **What material is the 4” sanitary water piping material that is to be removed? Has it ever been in use?**

Confirm existing pipe is 4” DIP, currently capped off for future install.

2. **The J-13 Appendix 1 is attached, was previously excluded from the package.**

3. **The current Bid Due Date of 2/22/2023 is changed to read 3/1/2023, an extension of 7 days.**

Include a signed and acknowledged copy of this Amendment with your proposal.

	10A. Fluor BWXT Portsmouth LLC Mark Pollard		
9B. CONTRACTOR/OFFEROR	9C. DATE SIGNED	10B.	10C. DATE SIGNED
_____		_____	2/21/2023

<i>(Signature of person authorized to sign)</i>		<i>(Signature)</i>	
---	--	--------------------	--